



N: DoP LUX FEP-FEV_indB1

DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

Unique identification code of the product-type:

CERTILUX FEP

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11 paragraph 4: Information given on the tracking label:

Order confirmation Number + Product Number + Date of production

- 3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:
 - 3.1 Product description :

Natural smoke and heat exhaust ventilator (NSHEV) for wall installation with polycarbonate or glass blades.

- 3.2 Installation and implementation conditions in accordance with the certified performances
- Wall installation from 0° to 30° except 0° for frame D
- Dimensional range: L and H are the throat dimensions of the product

L = width in m and H = height in m 0,503 \le H \le 3,018 and 0,5 \le L \le 2 with polycarbonate blades 0,503 \le H \le 2,028 et 0,5 \le L \le 1,600 with glass blades

With $0.25m^2 \le A_v^* \le 5m$ and $0.25m^2 \le A_v^* \le 4m^2$ *: $A_v = L \times H$

3.3 Mode of operation :

Electrical opening and closing

Voltage $U_a = U_c = 24 \text{ Vcc}$ -Wattage $P_a = P_c$ absorbed in a steady state

- 12 W for products from 3 and 4 blades.
- 60 W for products 5 blades and more.

3.4 Possible options:

Open / close position switches
Thermal device release (according to the current standard).
Small lateral windshields except for frame D.

4. Name, registered trade name or trade mark , in conformity with article 11, paragraph 5:

Company name: SOUCHIER-BOULLET SAS 11 rue des Campanules CS 30066 77436 MARNE LA VALLEE Cedex 2 France <u>Production unit</u>: SOUCHIER-BOULLET SAS 11 rue du 47^{ème} R.A. 70400 HERICOURT France

System or systems of assessment and verification of constancy of performance of the construction product in accordance to Annex V.

The notified body **TÜV Rheinland N° 0336** performed the determination of the product type on the basis of type testing, type calculation of the product, the initial inspection of the manufacturing plant and the factory production control and the continuous surveillance, assessment and evaluation of the factory production control under system 1 and issued the certificate of constancy of performance N°

CE Certificate N°0336 – CPR – 6742-1-2











N: DoP LUX FEP-FEV indB1

DECLARATION OF PERFORMANCE OF SMOKE AND HEAT CONTROL SYSTEMS

9. Declared performances:

Essential characteristics	Performance
Nominal activation conditions / sensitivity, as:	
Initiation device	present
Opening mechanism	present
Inputs and outputs	present
Response delay (response time), as:	
Reliability	
Opening under (snow, wind) load	117
Low ambient temperature	≤ 60 s
Fire Performance	
Operational reliability, as:	
Reliability	Re 1000 (+10 000), Type I
Effectiveness of smoke/hot gas extraction, as:	1
Aerodynamic free area	$A_a = A_v^* \times Cv^{**}$
Performance parameters under fire conditions, as:	
Resistance to heat	B ₃₀₀ 30
Mechanical stability	ΔAthroat < 10 %
Reaction to fire	
Glass blade	A1
Polycarbonate blade	B-s 1;d0
Performance under environnemental conditions, as:	
Opening under load	SL NPD
Low ambient temperature	T(-15)
Stability under wind load	WL 1500
Resistance to wind-induced vibration (where included)	ω_0 : > 10Hz, δ : >0,1
Resistance to heat	B ₃₀₀ 30
Durability, as:	
Response delay (response time)	≤ 60 s
Operational reliability	Re 1000 (+10 000)
Performance parameters under fire conditions	≤ 60 s; ΔA _{throat} < 10 %

**Definition of flow coefficient

<u>0,25 ≤Av≤ 5 m²</u>	500 ≤ L < 1000	1000 ≤ L ≤ 2000
H < 1000	Cv = 0,50	Cv = 0,50
H ≥ 1000	Cv = 0,50	Cv = 0,62

10. The performance of the product identified in points 1 et 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by: David Maillart - R&D Manager

The 20/04/2018 In Lognes





